


- 1** PROPOSER TO RUN ETHERNET CAT 5E/6 FROM NEW JACE TO MECH-ELEC CLOSET ADJACENT TO MAIN OFFICE.
- 2** PROPOSER TO RUN BACNET MS/TP CABLE FROM POWER MONITORING DEVICE IN NEW SWITCHGEAR TO JACE. (EXPECTED TO BE DIRECTLY BELOW CUSTODIAL OFFICE). ADDRESSING AND COMMUNICATIONS SETTINGS ARE TO BE COORDINATED WITH CMSD'S MASTER SYSTEMS INTEGRATOR PRIOR TO INSTALLATION.

NOTE:
 All wiring shall be in accordance with the Project Specifications, the National Electrical Code and any applicable local codes. All wiring shall be installed in the conduit types specified in the Project Electrical Specifications unless otherwise allowed by the National Electrical Code or applicable local codes. Where plenum rated cable wiring is allowed it shall be run parallel to or at right angles to the structure, properly supported and installed in a neat and workmanlike manner.

 2305 E. AURORA RD. TWINSBURG, OH 44087	DESCRIPTION	DATE	BY	SCALE:	NTS	CMSD BROOKLAWN-NTW ELECTRICAL SYSTEM INTEGRATION WIRING COPYRIGHT © AGM ENERGY SERVICES 2018	SHEET:	PROJECT #:
	ADDENDUM NO. 4	11/28/18		DRAWN:	LSH		SK-01	80634
				CHECKED:				1 OF 1
				ORIG. DATE:	11/28/18			