


**CLEVELAND
METROPOLITAN
SCHOOL DISTRICT**

Purchasing Department 1111 Superior
Avenue E, Suite 1800
Cleveland, Ohio 44114
Ph: (216) 838-0418 Fax: (216) 436-5118

November 29, 2018

To: All Vendors

From: Seletha R. Thompson 
Purchasing Analyst

Re: **Addendum #4 for RFP 21260 – Brooklawn New Tech West Phase 1 Electrical Services Upgrade**

*Below is **Addendum #4 for RFP #21260**. This addendum supplements and amends the items in the Specifications. This addendum must be noted on the Addendum Acknowledgement Form found in the RFP. Failing to acknowledge this Addendum on the Addendum Acknowledgement Form may cause the proposal to be rejected.*

Points of Clarity:

1. Clarification to communication cable run for JACE noted in Addendum No. 3 – *Refer to attached SK-01 Systems Integration Wiring sketch. Proposer is to run ethernet CAT 5E/6 from the JACE to the noted Mechanical-Electrical closet adjacent to the Main Office and coordinate installation with CMSD IT and Master Systems Integrator.*
2. Clarification to Overall Specification Section 1.2; 9. Temperature Control System: Electric Power Meter – *Proposers are to provide a power monitoring device, either integral to the new switchgear used or as a separate device. The preferred power monitor is a Veris E2X Series as noted in the attached product sheet, or equivalent. Regardless of type, the power monitor shall be configured for BACnet MS/TP communication, which the proposer will run to the new JACE 8000 being installed in the custodial office. Refer to attached SK-01 detail.*

Attachments:

1. SK-01 Systems Integration Wiring sketch
2. Veris Enercept E2X Series Power Monitor product sheet

BID DUE DATE

REMINDER: RFP 21260 – Brooklawn New Tech West Phase 1 Electrical Services Upgrade response is

Due December 5, 2018 at 1:00 PM (EST)

--End of Addendum 4--