



**CLEVELAND
METROPOLITAN
SCHOOL DISTRICT**

Purchasing Department 1111 Superior
Avenue E, Suite 1800
Cleveland, Ohio 44114
Ph: (216) 838-0418 Fax: (216) 436-5118

February 26, 2019

To: All Vendors

From: Seletha R. Thompson *SR*
Purchasing Analyst

Re: Addendum #2 for RFP 21269 – R G Jones Parking Lot Addition

*Below is Addendum #2 for RFP #21269. This addendum supplements and amends the items in the Specifications. This addendum **must be noted** on the Addendum Acknowledgement Form found in the RFP. Failing to acknowledge this Addendum on the Addendum Acknowledgement Form may cause the proposal to be rejected.*

R G Jones Parking Lot Addition

This Addendum #2 reflects the following:

- Clarification as to Bonding Requirements
- Response to Questions

Bonding Requirements

A certified check for 10% of the total amount of the bid payable to the Treasurer of the Cleveland Metropolitan School District, or a satisfactory bid bond executed by the bidder and a Surety company shall be submitted with each bid on a form supplied by the bondsman. The Surety Company must be licensed to do business in the State of Ohio and acceptable to the Chief Financial and Administrative Officer. The successful bidder will be required to furnish a satisfactory performance bond amounting to 100% of the contract amount.

Response to Questions

1. Clarification of construction testing required by the Contractor during construction

Answer:

- a. Proof roll existing grade.
- b. 1 concrete test per 50 cubic yards placed or one test per days placement.
- c. Concrete test shall include 1- 7 day break and 3 - 28 day breaks. Air, Slump and temperature.
- d. Compaction pavement 304 aggregate base.
- e. Compaction testing on intermediate and surface course asphalt.

This Addendum shall hereby be and become a part of the Contract Documents the same as if originally bound thereto.

Each bidder shall acknowledge receipt of this Addendum in your response to proposal or bid.

Reminder: RFP 21269 – R G Jones Parking Lot Addition

Responses are due

March 8, 2019 no later than 1:00 PM (EST)

--End of Addendum #2--