

# FPB SCHOOL INSPECTION FORM

*\*SAMPLE\**

Name of School: \_\_\_\_\_ Date: 9-6-16 + 9-28-16

Address: \_\_\_\_\_

Principal: \_\_\_\_\_ Phone: \_\_\_\_\_

Custodian: \_\_\_\_\_ Phone: \_\_\_\_\_

Grades Attending: PRE K THRU 12 No. of Students: 8

\* Inspection of Preschool classroom(s) shall be conducted. With letter 16 issued if in compliance

Stories: 3 Basic Construction Type: IV

8 STUDENTS MD/AUTISTIC - 2ND FLR.

## Fire Safety and Evacuation Plans (O.A.C. 404 and 405)

YES NO

On Premises (O.A.C. 404.4)

Last Updated (O.A.C. 404.5) Aug. 2016

(NO HOMEWORK SECURITY TEMPLATE)

## FIRE DRILLS (O.R.C. 3737.73 and O.A.C. 405)

YES NO

Conducted Monthly  
All Person Evacuated

✓ ✓

Records on Premises

Does Records Include \* AREAS OF REFUGE

Time of Drill  
Date of Drill  
Weather Conditions  
No. of Occupants Evacuated  
Total Evacuation Time

✓  
✓  
✓  
✓  
✓

## TORNADO SHELTER (O.A.C. 409)

YES NO

Scale Drawing Indicating Tornado Shelter Areas

Drills Conducted Monthly During Tornado Season (4/1-7/31)

✓ ✓

## AREAS OF EGRESS

Panic Hardware Functional  
Exit Signs Illuminated  
Emergency Lights Functional  
All Means Of Egress Unobstructed

✓  
✓  
✓  
✓

## FIRE PROTECTION

Fire Alarm System Functional  
Last Tested 8/14/16 (If Required)  
Extinguishers Mounted  
Last Tested JUNE 2016 (If Required)  
Hood Suppression System Functional  
Last Tested N/A

✓  
✓  
✓  
✓

Water Based Fire Protection System(s) Type & Test Dates: 2013+ 2014; ABATEMENT ORDER,

NO RECORDS FOR FIRE PUMP(S); SPRINKLERS HAVE TAG ONLY FOR 2014. NO TEST RECORD  
3RD FLR. PLANS (RISER) HAS - LICENSED CONTRACTOR TEST REC'D.

*\* AREA OF REFUGE LABELING*

*\* 3RD FLR - GAS, OFF*

**STORAGE**

Proper Storage of Flammable Liquids

YES

NO

Proper Storage Combustible Material

Proper Storage of Chemicals (Lab)

NOT APPLICABLE

Last Inventoried: N/A

Other Storage Proper

N/A

**Decorative Material Flame Resistant**

**Comment on all "NO" Answers or other violation noted:**

**SPECIAL CIRCUMSTANCES**

Industrial Arts, Art Rooms, Laboratories, Underground/Above Ground Tanks

**Pre-School**

Inspection Conducted (Yes/No)

Letter 16 Issued (Yes/No)

**Violations**

Violations (Yes/No): C.O. 389.94

No. of Violation Noted: # ABATEMENT 04226

**Action Taken:**


(Verbal) Yes/No

Letter of Violation (Yes/No)

Violation Notice (s): # 04226 (ABATEMENT)

**Violation Letter shall be issued for all violation that is not remedied on the spot.**

- ABATEMENT FORWARDED TO LT. STANBACK CFD/FPB; TO BE RESOLVED w/ CMSD



Inspector Name